

**TEST WATER BEFORE TASTE****TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****District Level Water Testing Laboratory**

TWAD Board. No. 6/24, Lalbhagadur Sasthiri St, Periakuppam, Thiruvallur - 602 001

TEST REPORT

Ph : 044-27663937

ReportNo:	TRL/2024/ 29627 - 1	Report Issue Date :	05.07.2024
Invoice Details:	15381Dt 04.07.2024 Amount:1180/-		Page 1 of 1

Client Name & Address	:	Marian School of Excellence No.199.Palavedu Main Road, IAF Avadi, Chennai- 600055.
Contact No / Email.ID	:	
Sample Name	:	Water
Sample Number	:	29627 - 1
Sample Description	:	RO
Sample Submitted by	:	Mr. Geo francis girish
Location & Date	:	Marian School of Excellence - Campus& 03.07.2024
Quantity of sample Received	:	2 Litre
Sample Container	:	Jerry Cane
Sample Condition on Receipt	:	Good
Sample Received On	:	03.07.2024
Test Commenced on	:	03.07.2024
Test Completed on	:	04.07.2024
Environmental Condition	:	27.6°C – 27.9°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Odour	IS 3025 Part 5 : 1983	--	Agreeable	Agreeable	Agreeable
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0.0	1	5
4	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	50	500	2000
5	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	72	-	-
6	P - Alkalinity	IS 3025–Part 23-1983	mg/L	-	-	-
7	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	2	75	200
8	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	1	30	100
9	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0.0	0.3	1
10	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	-	0.1	0.3
11	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0.0	0.5	0.5
12	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO ₂ B	mg/L	0.00	-	-
13	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.00	-	-
14	Tidys 4 hr. test	APHA 23rd Edition 2017 – 4500 O - B	mg/L	0.0	-	-
15	Residual Chlorine	IS/APHA	mg/L	0.0	0.0	1.0
BACTERIOLOGICAL EXAMINATION						
16	Fecal Coliform	IS/APHA	CFU/100ML	0	0	0

Remark: The given water sample is chemically potable.

....End of the report.....

T.P. San 05.7.24
Authorised Signatory**QUALITY MANAGER**
District Water Testing Laboratory
TWAD Board, RWS Division
Thiruvallur**Note:**

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 6/24, Lalbhagadur Sasthiri Street, Periyakuppam,

Thiruvallur - 602001. Phone : 044 - 27663937 E.mail:tvrlabtwadboard@gmail.com



TEST REPORT

Report No:	TRL/2024/ 29627 - 1	Report Issue Date :	05.07.2024	Page No : 01 of 01
Invoice Details:	15381 Dt 04.07.2024 Amount:1180/-	ULR No	TC103922300000036F	

Client Name & Address		: Marian School of Excellence No.199.Palavedu Main Road, Contact No / Email.ID IAF Avadi, Chennai -600 055.				
Sample Name	:	Water				
Sample Number	:	29627- 1				
Sample Description	:	RO				
Sample Submitted by	:	Mr. Geo francis girish				
Location & Date	:	Marian School of Excellence - Campus & 03.07.2024				
Quantity of sample Received	:	2 Litre				
Sample Container	:	Jerry Cane				
Sample Condition on Receipt	:	Good				
Sample Received On	:	03.07.2024				
Test Commenced on	:	03.07.2024				
Test Completed on	:	04.07.2024				
Environmental Condition	:	27.6°C – 27.9°C				
S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25 ^o C	-	IS 3025 Part 11-1983	6.97	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	12	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-1986	24	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	8	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24-1986	4	200	400
6	Nitrate as NO ₃	mg/L	APHA 23rd Edition 2017- 4500 -NO3 B	0	45	45
7	Fluoride as F	mg/L	APIIA 23rd Edition 2017 - 4500- F-D	0.0	1.0	1.5

Remark: The tested sample conformed to IS:10500:2012(RA: 2019)drinking water specification with respect to above tested parameters. The Decision rule is applicable.

.....End of the report.....

Authorised Signatory

QUALITY MANAGER

District Water Testing Laboratory
TWAD Board, RWS Division

Thiruvallur

Note:-

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.